

Certificate of Compliance

Certificate Number 083107-EX5148
Report Reference Ex5148 - August 28, 2003
Issue Date 2007 August 31

Page 1 of 1



Issued to: **VAL-MATIC VALVE & MFG. CORP.**
905 Riverside Dr.
Elmhurst, IL 60126

This is to certify that representative samples of

Air Release Valves for Fire Pumps

Models:
15A, 15A.2, 15A.3, 22.4, 22.3, 22.7, 22.9 for use with split case fire pumps.
101 WST, 102 WST, 103 WST, 101 ST, 102 ST, 103 ST for use with vertical turbine fire pumps.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

The basic requirements used to investigate products in this category are contained in UL Subject 1478A:
"Outline of Investigation for Pressure Relief Valves for Sprinkler Systems."

Additional Information:

This category covers air release valves intended for use with centrifugal fire pumps to vent air from the casing while in the standby and operational modes. Requirements for the installation and use of these devices are contained in ANSI/NFPA 20, "Standard for the Installation of Stationary Pumps for Fire Protection."

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Andrew Gurvey
Underwriters Laboratories Inc.

Handwritten signature of Andrew Gurvey in black ink, written over a light brown background.

Reviewed by:

Matthew Tennenbaum
Underwriters Laboratories Inc.

Handwritten signature of Matthew Tennenbaum in black ink, written over a light brown background.

UL CERTIFICATE FOR AIR RELEASE VALVES

DATE 9-8-09

VAL-MATIC® VALVE AND MANUFACTURING CORP.

DRWG. NO.

SS-2478